



Certificate number 17407 Rev.0 Replaces -

Issued 22/09/2023 First edition 22/09/2023

Report number PKC0012645 Expiry date 21/09/2028

Page 1 of 1

Certificate of Type Testing Conformity

License holder: Omnis Power Engineering S.p.A.

Via Enrico Besana 6 – 20122 Milano, Italy

Production site(s): Omnis Power EU

Ringuvos gatvè 74 - LT45245 Kaunas, Lithuania

Product: Photovoltaic (PV) module

Model(s): OP430M54-NT5-BF

Kiwa Cermet Italia hereby declares that the product can be considered complying to the type testing based upon the following aspects:

IEC 61215-1:2021 / EN IEC 61215-1:2021
 Terrestrial photovoltaic (PV) modules – Design qualification and type approval – Part 1: Test requirements

• IEC 61215-1-1:2021 / EN IEC 61215-1-1:2021 Terrestrial photovoltaic (PV) modules – Design qualification and type approval – Part 1-1: Special requirements for testing of crystalline silicon photovoltaic (PV) modules

IEC 61215-2:2021 / EN IEC 61215-2:2021
 Terrestrial photovoltaic (PV) modules – Design qualification and type approval – Part 2: Test procedures

Test MQT 17 - Hail test Spheres reference diameter = 45 mm. Spheres reference speed = 30.7 m/sec

Kiwa Cermet Italia Guideline "TD Ki – 0409, Solar Products and Components"

Modifications to the product, may imply re-testing and re-certification.

This type testing certificate does not include the Initial and the Periodic Inspection of the production samples and does not certify the quality and safety of the serial products.

This certificate is issued in accordance with the Kiwa Cermet Italia regulations for Product Certification. Publication of the certificate is allowed.

The validity of this certificate can be verified on request at the following e-mail address: energy@kiwacermet.it. Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

President

Giampiero Belcredi

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta
all'attività di direzione e
coordinamento di Kiwa Italia
Holding Srl

Via Cadriano, 23 40057 Granarolo dell'Emilia (BO) Tel +39.051.459.3.111 Fax +39.051.763.382 E-mail: info@kiwacermet.it www.kiwa.it

Additional Information:

Laboratory test reports nr.: L0012645 rev.01.

